

March 29, 2012

ADDENDUM #7

Project: 2012 Architectural & Electrical Renovations – Hudson Area Schools
Hudson, Michigan

Engineer: Dailey Engineering Inc.
8485 Stephenson Rd.
Onsted, Michigan 49265

This addendum provides clarification and information regarding the Bidding Documents issued March 9, 2012 for the 2012 Architectural & Electrical Renovations – Hudson Area Schools, Hudson, Michigan, and hereby become a part of the Bidding Documents for the Project.

Each Contractor shall review this information and follow the instructions for any and all changes, and shall include in his Bid Amount any changes in cost due to this Addendum.

DRAWING ITEMS:

1. Drawing 200-A6.1: Wherever the door schedule gives a door size, this indicates that a new door is to be included in the scope of work. In regards to the floor plans (drawings 200-A1.3 through 200-A2.88), new doors are intended to be shown in red. However some of these new doors were inadvertently shown in black. In these cases, the door schedule shall govern. New frames are required for new doors, unless the door schedule references “Note C”, which calls for the existing frame to remain.
2. Drawing 200-A6.2 is revised as follows: For corridor 4, delete item 13 and note #5. There is no ceiling work in corridor 4 (existing to remain as is).

BID DIVISION 200-3 ITEMS:

1. The scope of work shall include specification sections 08340 –Rolling Counter Fire Doors and 08350 – Rolling Grilles.