

March 29, 2012

ADDENDUM #6

Project: 2012 Architectural & Electrical Renovations – Hudson Area Schools
Hudson, Michigan

Engineer: Dailey Engineering Inc.
8485 Stephenson Rd.
Onsted, Michigan 49265

This addendum provides clarification and information regarding the Bidding Documents issued March 9, 2012 for the 2012 Architectural & Electrical Renovations – Hudson Area Schools, Hudson, Michigan, and hereby become a part of the Bidding Documents for the Project.

Each Contractor shall review this information and follow the instructions for any and all changes, and shall include in his Bid Amount any changes in cost due to this Addendum.

SPECIFICATION CHANGES:

1. Specification section 9502.4(A) shall be revised to change the required ceiling tile to Armstrong School Zone Fine Fissured, 24"x48"x3/4", Class A (Number 1714). The intent is that in any/all areas where new grid is being installed, the new ceiling tile shall be the School Zone Fine Fissured tile. In areas where grid is remaining, any required ceiling tile replacement shall be done with existing tile (which is Armstrong 915 Textured Fireguard, 5/8" thickness).