

Sue Moranti
 Purchasing Manager
 City of Novi
 45175 W. Ten Mile Rd.
 Novi, MI 48375-3024
 (248) 347-0446
 (248) 735-5682 fax
 smoranti@cityofnovi.org



cityofnovi.org

Fax

To: William Wiemer - Axiom Construction Services
Fax: 248.446.1105
Date: April 13, 2012
Pages: 2

Good afternoon,

Please find a "Post Bid Addendum" attached for the Novi Field Services Complex Door and Window Replacement project. We are only sending this to the firms that submitted bids on the project.

We are seeking "deduct" prices for some revised specifications in an attempt to reduce the cost of the project.

If you are interested in providing these figures, please fax the completed Addendum form to me by 3:00 p.m. on Friday, April 20, 2012.

Sincerely,
 Sue Moranti

POST BID ADDENDUM



Response due by: Friday, April 20, 2012 by 3:00 p.m.
Fax to: 248-735-5682 Attention: Sue Morant, Purchasing Manager

POST BID ADDENDUM NO: 01
PROJECT: Novi Field Services Complex
Door and Window Replacement
26300 Lee Bagole Drive,
Novi, MI 48375

DATE: 04/13/12
PROJECT NO.: 0163-12-0021
PAGE 1 OF 1
ARCHITECT: OHM
CONTRACT DATE:

INTENT: This addendum is issued to clarify or correct the bidding documents.
Below are descriptions of possible changes to the scope of the project. Provide pricing for the amount to be deducted for each of the following alternates:

SPECIFICATIONS

Section 081113, Part 2.2, A, add the following:
"Provide a 1" insulated aluminum panel at all renovated transoms. Panel is to be installed using manufacturer's recommended clips, sealant and necessary separators at metals. Panel is to have a baked on enamel finish."

Deduct _____

Section 087100, Part 3.2, Hardware set No.1, item 3, Exit Device, revise as follows:
"As a basis of design provide panic exit hardware by Von Duprin, model 99L-03-4-US 26, or equal. Revise the doors to eliminate the mortise preparation and to include the above rim device panic exit hardware."

Deduct _____

DRAWINGS

Sheet A401, Door, Frame and Hardware Schedule, revise per the following:
Revise all door sizes to be 7'-0" high doors.

Deduct _____

Sheet A201
Eliminate all intermediate horizontal mullions.

Deduct _____

Because of the above changes, re-evaluate the projected number of days for completion. The total number of days required for completion is:

The Owner may elect to accept any, none or all of the above deduct prices.

Company Name: _____

Agent's Signature: _____

Date: _____

4)

3)

2)

1)