



architects  
engineers  
www.woldae.com

333 W. Seventh Street  
Three Hundred Twenty  
Royal Oak, MI 48067

tel 248 284 0611  
fax 248 284 0615  
mail@woldae.com

**To:** Prospective Bidders  
**From:** Wold Architects and Engineers *WJ*  
**Date:** April 17, 2013  
**Comm. No:** 134003

**Subject:** Addendum No. 3 for Bidding Documents for the: WIHi Science Lab Remodel  
Ypsilanti, Michigan 48198

BIDS DUE APRIL 19, 2013 AT 2:00 P.M.

This addendum forms a part of the Contract Documents dated April 5, 2013. Acknowledge receipt of this Addendum on the space provided on the Bid Form. Failure to do so may result in disqualification of Bid.

This Addendum consists of one (1) typed sheet:

#### DRAWINGS

1. DRAWING A2.01 INTERIOR / EXTERIOR ELEVATIONS, SECTIONS AND DETAILS.
  - A. At the Floor Finish Plan Legend add "VCT 5 – FIELD COLOR", which is to be all field tile not already identified in the legend or plan at drawing G7-Main Level Floor Finish Plan – Area 'A'. The color will be selected by the architect from the manufacturer's full color line.
2. DRAWING E1.00 ELECTRICAL PLANS.
  - A. Refer to Electrical Plan – Demolition. Apply keyed note "6" to East Wall of classroom to include removal of existing raceway not originally shown.
  - B. Refer to Power Plan – New Work. At ERU-1 change keyed note from 13 to 12. Revise keyed note 12 to read, "Provide separate combination motor starter and disconnect for both MAU-1 and ERU-1 Service." At Motor Starter/disconnect for ERU-1 show connection to Panel "A", circuits 31 and 33. Motor starter/disconnect for MAU section shall remain in Panel "A", circuits 35 and 37.
  - C. (E) Panel A Schedule.
    1. Revise circuits 35 and 37 to be for "MAU-1 Section".
    2. Add new circuit at 31 and 33 to be for "ERU-1 Section", with a O.C. Prot. of 20A.

END OF ADDENDUM #3

Minnesota  
Illinois  
Michigan  
Colorado  
Iowa