

WAKELY ASSOCIATES, INC.  
ARCHITECTS  
30500 Van Dyke Avenue Suite M-7  
Warren, Michigan 48093

ADDENDUM NO. TWO  
WARREN WOODS PUBLIC SCHOOLS  
HAWTHORN EARLY CHILDHOOD CENTER  
RENOVATIONS  
Page 1 of 1 (write up only)

March 10, 2015

ADDENDUM NO. TWO to the plans and specifications for the WARREN WOODS PUBLIC SCHOOLS, HAWTHORN EARLY CHILDHOOD CENTER, RENOVATIONS, Architect's Project No. 141596, dated February 23, 2015.

The above plans and specifications are modified, supplemented or augmented as follows, and this ADDENDUM NO. TWO, is hereby made a part of the contract documents.

**MECHANICAL**

**ITEM NO. M1:** The following is clarified for the New Mechanical Units Interface with the existing BMS System:

The following sensors, and points to be interfaced with the existing NOVAR system:

- . Return air temp.
- . Supply air temp.
- . Space air temp.
- . Remote on/off.
- . Unit alarm.

The roof top units will be furnished with local panels for :

Fan on/off, cooling enable, heating enable, space temperature adjustments,

Automatic enthalpy based economizer controls to be furnished with the units.

Wiring of the local control panels to the roof top units control by the temperature controls contractor.

**END OF ADDENDUM NO. 2**