



CLARK
Construction Company

3535 Moores River Drive • PO Box 40087 • Lansing, MI 48901
517.372.0940 fax: 517.372.0668

April 7, 2016

ADDENDUM NO. 2

PROJECT: Saline Area Schools 2015 Bond Program
2016 Projects Phase 1
DESCRIPTION: Architectural Renovation
BID PACKAGE RELEASE NUMBER: 1
CLARK PROJECT NO: 2714

BID PROPOSAL DUE DATE/TIME: **UNCHANGED**
11:00 AM, Tuesday, April 12, 2016

The following clarifications and/or Changes made to the Contract Documents are hereby made part of the Contract Documents.

The general character of the Work clarified or revised by this Addendum shall be the same as required by the complete set of Contract Documents. All incidentals required in connection with the Work of this Addendum shall be included in the Scope of Work even though not specifically specified.

All bidders shall be held responsible to review the Addendum and to include in its Bid Proposal all Work reasonably inferred to be included in its Scope of Work.

Acknowledge receipt of this Addendum in the space provided on the Bid Proposal Form.

A. Architect/Engineer Documentation:

1. None.

B. Division 00 – Bidding and Contract Requirement Modifications:

- 1. FOR BID CATEGORY 1C – PRE-PURCHASED GENERATOR ONLY. Section 001100 – Advertisement/Invitation for Bids. REVISE ARTICLE 2.2. Proposal must be delivered not later than 11:00 am Local Time, Monday, April 11, 2016. ALL OTHER CATEGORIES ARE UNCHANGED.**

2. **FOR BID CATEGORY 1C – PRE-PURCHASED GENERATOR ONLY. Section 001100 – Advertisement/Invitation for Bids. REVISE ARTICLE 2.4. Bids will be opened publicly at 1:00 pm Local Time, Monday, April 11, 2016 at Saline Alternative High School, 7265 Saline – Ann Arbor Road, Saline, MI 48176. ALL OTHER CATEGORIES ARE UNCHANGED.**
3. Section 002416 – Bid Category Specific Notes Bid Category 01D – Finish Carpentry, Drywall, Acoustical and General Trades. DELETE BASE SPECIFICATION 087143 FRP FLUSH DOORS.
4. Section 002416 – Bid Category Specific Notes Bid Category 01D – Finish Carpentry, Drywall, Acoustical and General Trades. ADD REFERENCE SPECIFICATION 087200 ACCESS CONTROL SYSTEM.
5. Section 002416 – Bid Category Specific Notes Bid Category 01D – Finish Carpentry, Drywall, Acoustical and General Trades. ADD INCLUDE ITEM 31. Furnish door hardware as listed in specification section 087200. This hardware if furnished by this contractor it should also be installed by this contractor. Final connection shall be others.
6. Section 002416 – Bid Category Specific Notes Bid Category 01D – Metal Roofing. Add Include Item #20. Include an allowance of \$10,000 for flashing of roof curbs and patching of roofing due to mechanical and electrical demolition not shown on these documents.
7. Section 002416 – Bid Category Specific Notes Bid Category 01E – Glass & Glazing. ADD BASE SPECIFICATION 087143 FRP FLUSH DOORS.

C. Questions

- Q1. At Pleasant Ridge is there an accent paint stripe in the corridor. Currently the P-5 accent paint stripe is shown throughout the classrooms and in many other rooms, but not in the corridors, where there is an accent stripe currently exists.
- A1. Yes provide this accent paint stripe in the corridor.
- Q2. At the High School, should we expect any touch up painting as there is demolition indicated but no painting work is shown on the drawings.
- A2. Include painting where shown.
- Q3. In specification section 263213 article 2.2.I.1 states the generator sound level cannot exceed 75.9 dBA. Is it possible to provide sound attenuating enclosure to meet this requirement even though article 2.6.A says non-sound attenuating.
- A3. Yes the enclosure can be sound attenuating to meet the required sound levels.
- Q4. In addendum #1 it revised metal roofing color from standard to a custom, is this correct.
- A4. The metal roofing color shall be a standard per the original specification.

Q5.The drawings specifies that the roller shades are to start from the second mullion down from the top, and the roller schedule has the window dimensions listed on the same drawing. Do the dimensions in the roller schedule take into account the second mullion down height for RS-6 through RS-8L?

A5.Yes.

Q6.In room C124 is there supposed to be roller shades for each window or only the window on the north side of the room?

A6.Just the north side of the room.

END OF SECTION