

ADDENDUM

Project Name: Village of Beverly Hills **Addendum No: One (3)**
Village Hall Office Renovation

Project Number: 15-161 Issue Date: April 20, 2015
Project Location: The Village of Beverly Hills, Michigan

To the Contract Documents for the requested Village of Beverly Hills Village Hall Office Renovation.

This Addendum forms a part of the above described Contract Documents and supersedes, supplements or clarifies parts thereof to the extent defined by the terms set forth in this Addendum.

This addendum consists of (1) typed page.

Specifications:

Item Sp1 Section 083313 Coiling Counter Doors (not re-issued this Addendum):

A. Part 2, Products, 2.1 K. Door Finish:

1. Delete: "Baked Enamel or Powder Coat Finish: Color as selected by Architect form manufacturer's full range.
2. Add: " Clear Anodized finish"

Item Sp1 Section 122413 Roller Shades (not re-issued this Addendum):

A. Part 2, Products, 2.1 Roller Shades; H. Method of Installation:

1. Delete paragraphs #1, 1a.1; 1a.2; 1a.3; and 1a.4 in entirety and
2. Add paragraph 1 as follows:
 - a) 2.1. (H. 1): At locations where ceiling is directly adjacent to the shade housing, the unit is to be surface mounted to wall, or through ceiling / soffit into header with screws or other acceptable means of attachment. At these locations provide finished snap on fascia and end caps. Refer to drawings for locations.

****END OF ADDENDUM****