



CLARK
Construction Company

3535 Moores River Drive • PO Box 40087 • Lansing, MI 48901
517.372.0940 fax: 517.372.0668

10/30/2019

ADDENDUM NO. 2

PROJECT: DPS – Administrative Service Center
Remodeling
DESCRIPTION: Addendum No.2
BID PACKAGE RELEASE NUMBER: 1

BID PROPOSAL DUE DATE/TIME: 2:00 PM, Thursday, October 31, 2019

The following clarifications and/or Changes made to the Contract Documents are hereby made part of the Contract Documents.

The general character of the Work clarified or revised by this Addendum shall be the same as required by the complete set of Contract Documents. All incidentals required in connection with the Work of this Addendum shall be included in the Scope of Work even though not specifically specified.

All bidders shall be held responsible to review the Addendum and to include in its Bid Proposal all Work reasonably inferred to be included in its Scope of Work.

Acknowledge receipt of this Addendum in the space provided on the Bid Proposal Form.

A. Questions / Clarifications

1. Clarification 1:

- i.** Drawings E3.1, Note 1 indicates, “Relocated technology rack. Provide new receptacles as indicated. Circuit to maintain branch circuit. Extend conduit and wire as required”.
- ii.** Relocating technology rack, including extending data/comm wiring will be provided by Dearborn Public Schools and shall not be a part of this bid. New receptacles as shown and referenced in Note 1 shall be included in the base bid.

2. Clarification 2:

- i.** Drawing E3.1, Note 2 indicates, “Relocated telephone board. Extend all maintained conduit and wire as required”.
- ii.** This work will be completed directly by Dearborn Public Schools and shall not be included in the base bid.

3. Clarification 3:

- i.** “Technology Contractor” as indicated on E.02 shall be directly provided by Owner. All rough in per details shall be included in base bid by General Contractor, including but not limited to the wiremold required on existing walls. Coordinate location of rough in for Power/AV devices with Owner and Owner’s technology contractor prior to rough in per the documents.

END OF SECTION